

Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

WH Service Mark 2014 for Category D - Door/frame Assemblies

Standards: BS 476 Part 22 (1987), EN 1634-1 (2014)

Certificate number: WHI17-29215806

Organization: Bin Ghurair Metal Industries L.L.C.

Plot No. 597-400

Dubai Investment Park 2

Dubai

United Arab Emirates

Product: Bin Ghurair - EN 1634-1/BS 476 Part 22 - 240 minute
Swinging Type Fire Door & Frame Assembly (Honeycomb Infill)

Spec ID: 42146

Fire Rating: 4 Hour Fire Rated

Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: July 31, 2017

Date of expiry: December 31, 2020

Issue status: 4

Authorized By: 

Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.

545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA

Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

FIRE RESISTANT PRODUCT AND COMPONENTS

Fire door and frame assembly - Honeycomb infill type

PRODUCT COVERED

Single and Double Leaf Steel Fire Door and Frame

PRODUCT DESCRIPTION

Single and Pair of swinging, hollow metal type, honeycomb infill fire doors intended for use in masonry constructions.

The door frame can be installed with or without grouting.

Limitations:

Minimum latch throw - 11mm.

Minimum 3-point latching required for double leaf doors (top and bottom flushbolts on the inactive leaf and center latch for the active leaf).

Maximum tested sizes:

Single door frame - 1200mm x 2800mm x 150mm (w x h x jamb depth)

Single door leaf - 1094mm x 2737mm x 45mm (w x h x thickness)

Double door frame - 2400 x 2800mm x 150mm (w x h x jamb depth)

Double door leaf - 1145mm x 2737mm x 45mm (w x h x thickness)

Vision Panel Glass - 225mm x 725mm x 5mm (w x h x thickness)

Allowed Extended Sizes for 240 minute fire rating:

	Width (mm)	Height (mm)	Area (sq. m)
Single Door Frame	1380 (at 2920mm height)	3220 (at 1251mm width)	4.03
Single Door Leaf	1258 (at 2853mm height)	3147 (at 1140mm width)	3.59
Double Door Frame	2760 (at 2920mm height)	3220 (at 2503mm width)	8.06
Double Door Leaf	1316 (at 2857mm height)	3147 (at 1194mm width)	3.76

Allowed Extended Sizes for the vision panel glass for 240 minute fire rating:

	Width (mm)	Height (mm)	Area (sq. m)
Vision panel glass	258 (at 736mm height)	833 (at 228mm width)	0.19

Allowed Extended Sizes for 120 minute fire rating:

	Width (mm)	Height (mm)	Area (sq. m)
Single Door Frame	1560 (at 2903mm height)	3640 (at 1244mm width)	4.53
Single Door Leaf	1422 (at 2834mm height)	3558 (at 1132mm width)	4.03
Double Door Frame	3120 (at 2907mm height)	3640 (at 2491mm width)	9.07
Double Door Leaf	1488 (at 2836mm height)	3558 (at 1186mm width)	4.22

NOTE: Transom panel can be added in the honeycomb infill door assemblies up to a total **maximum height (including transom panel) of 3300mm for a maximum 120 minutes Integrity (E) rating.**

- The door frame jambs and head are to be extended in height to the top of the structural opening.
- The transom panel, up to 560mm high, should be of the same construction as the door leaves and must be separated from the door leaves by a transom bar.
- The panels must be fastened to the door frame using 5mm diameter bolts via 45mm x 45mm x 60mm-long x 3mm-thick steel cleats; the location of the cleats are as shown in drawings in Appendix A.
- Where the doorset is fitted with a transom panel, the maximum height of the doorset, including the transom panel, must not exceed 3300mm.

RATINGS

The single and double door and frame assemblies have been evaluated in accordance with EN 1634-1:2014 and BS 476 Part 22 standards and achieved the following ratings:

Integrity	240 Minutes
-----------	-------------