## CERTIFICATE OF COMPLIANCE

**Certificate Number** 

20130304-R27632

Report Reference

R27632-20130301

**Issue Date** 

2013-MARCH-04

Issued to:

MIDDLE EAST INSULATION LLC

JEBEL ALI INDUSTRIAL AREA 2 DUBAI, PO BOX 14225

UNITED ARAB EMIRATES

This is to certify that representative samples of

SWINGING-TYPE FIRE DOORS, POSITIVE-PRESSURE

TESTED; SWINGING-TYPE FIRE DOORS

See next page for Models

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Positive Pressure Fire Tests of Door Assemblies", UL 10C

Fire Tests of Door Assemblies", ANSI/UL 10B

**Additional Information:** 

See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle: with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.

William R. Carry

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="https://www.ul.com/contactus">www.ul.com/contactus</a>



## CERTIFICATE OF COMPLIANCE

Certificate Number
Report Reference

20130304-R27632 R27632-20130301 2013-MARCH-04

Issue Date

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

A single and a pair of swinging, steel stiffened, hollow metal type, rock wool construction, fire doors intended for 1-1/2h, 1h and 3/4h locations for use in masonry constructions

William R. Carry

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="https://www.ul.com/contactus">www.ul.com/contactus</a>

