

Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek WH US Mark for Category A - Doors - No Additional Edge-sealing System Required


Standards: UL 10(c) (2016)

Certificate number: WHI16-29215801

Organization: Bin Ghurair Metal Industries L.L.C.
Plot No. 597-400
Dubai Investment Park 2
Dubai
United Arab Emirates

Product: Bin Ghurair 90 Minutes Swinging Type Fire Doors
Spec ID: 37720
Fire Rating: 90 Min PP Category A Door
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: November 02, 2016
Date of expiry: December 31, 2024
Issue status: 7

Authorized By: 
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS

Category A Doors - Hollow Metal Steel Stiffened Rockwool Infill Type

PRODUCT COVERED

Steel Fire Doors

PRODUCT DESCRIPTION

Single and Pair of swinging, steel stiffened, hollow metal type, rockwool infill (80 kg/m³) fire doors intended for 1-1/2 hr, 1 hr & 3/4 hr locations for use in masonry constructions.

For use with listed and labeled steel fire door frames only.

Limitations:

Minimum latch throw of 19 mm (3/4 in.).

Maximum Door Size

Type	Size
Double	Each leaf - 1037 mm wide x 2332 mm high 2084 mm wide x 544 mm high (Transom Door)
Single	1037 mm wide x 2332 mm high 1042 mm wide x 544 mm high (Transom Door)

RATING

The above door is rated for 90 minutes of fire resistance to the following standards:

UL 10C