

# Certificate of Compliance



You have been awarded:

## **WH Service Mark 2014 for Category D - Door/frame Assemblies**

Standards: BS 476 Part 22 (1987), BS 476 Part 20 (1987)


Certificate number: WHI17-29215804

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

**Organization:** Bin Ghurair Metal Industries L.L.C.  
Plot No. 597-400  
Dubai Investment Park 2  
Dubai  
United Arab Emirates

**Product:** Bin Ghurair - BS 476 Part 22 - 60 minutes Swinging type fire door & frame assembly  
*Spec ID:* 41784  
*Fire Rating:* 1 Hour Fire Rating  
*Listing Information:* See following page(s)

**Certification body:** Intertek Testing Services NA, Inc.  
**Initial registration:** June 21, 2017  
**Date of expiry:** December 31, 2024  
**Issue status:** 4

Authorized By:   
**Jean-Philippe Kayl, Director of Certification**

Intertek Testing Services NA, Inc.  
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
Phone: 847-439-5667 Fax: 847-439-7320

[www.intertek.com](http://www.intertek.com)

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

# LISTING INFORMATION

## FIRE RESISTANT PRODUCT AND COMPONENTS

Fire door and frame assembly - Steel Stiffened Rockwool infill type

## PRODUCT COVERED

Double Leaf Steel Fire Door and Frame

## PRODUCT DESCRIPTION

Pair of swinging, steel stiffened, hollow metal type, rockwool infill (60 kg/m<sup>3</sup>) fire doors intended for use in masonry constructions.

The doors are to be installed in steel frames (with or without grouting).

Limitations:

Minimum latch throw - 11mm.

Maximum sizes:

Door Frame:

Width - 2558mm (at 2795mm height)

Height - 3082mm (at 2319mm width)

Total area - 7.15 m<sup>2</sup>

Door Leaf:

Width - 1216mm (at 2730mm height)

Height - 3013mm (at 1101mm width)

Total area - 3.32 m<sup>2</sup>

## RATINGS

The double door and frame assembly has been evaluated in accordance with BS 476-22, Method 8, Determination of the fire resistance of un-insulated doorsets and shutter assemblies and achieved the following ratings:

Integrity	86 Minutes
Insulation	N/A